

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:52 am

PWS ID: UTAH07046 **Name:** GRANTS SPRINGS
Legal Contact: USFS - ASHLEY NATIONAL FOREST SO
 LANCE VALENTINE
Address: 355 N VERNAL AVE
 VERNAL, UT 84078
Phone Number: 435-781-5142
City Served (Area):
County: DUCHESNE COUNTY
System Type: Non-community
Activity Status Cd: Active
Population: 64
Rating: Approved
Rating Date: 05/06/2010
Activity Status: Active
Last Inv Update: 08/18/2010
Last Snty Srv Dt: 10/15/2008
Surveyor: MICHAEL S MOSS
Oper Period: 5/30 to 9/15
Avg Daily Prod:
Total Dsgn Cap:
Total Emerg Cap:

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	VALENTINE, LANCE	FOREST ENGIN	435-781-5113		lvalentine@fs.fed.us

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	12
			12 Total Svc Connections

Storage

Total Storage: 720 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	2,000 GAL TANK	Ground	720 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	GRANT SPRING CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	GRANT SPRING	Active	SP				Yes	GW	Seasonal	5/30 to 9/15	

*Reports measured flow for wells, approved design capacity for all other sources.